



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(10) in WSD 3321/2025 T/J(765/2025)

6 March 2026

**Approval of “TAI-FLEX” Settlement Joints
(General Acceptance No. ZC20260142)**

Your letter dated 29 July 2025 and subsequent submissions received by this department up to 4 February 2026 refer.

Having considered the test reports ref. 244118PC250332B and 244119EN250175A issued on 26 January 2026 and 14 July 2025 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Taisei Kiko Co Ltd

Country of Origin: Japan

Brand: Tai-Flex

Details of Fitting: Ductile iron settlement joint with epoxy coating

Model: TF80

Size: 50mm, 80mm, 100mm, 150mm, 200mm, 250mm,
300mm, 350mm, 400mm, 450mm, 500mm, 600mm



Body Markings:

For 50mm:

TAI-FLEX TF80 TAISEIKIKO CO LTD
 MADE IN JAPAN BSEN 1092-2 PN16
 ト水 D 20

For others:

TAI-FLEX TF80 TAISEIKIKO CO LTD
 MADE IN JAPAN ト水 D 20
 BSEN 1092-2 PN16
 BS4504 (size)

Expiry Date:

5 March 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
 for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



TF80