



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (12) in WSD 3321/2025 T/J(822/2025)

9 March 2026

**Approval of “TOZEN” Flexible Joints
(General Acceptance No. ZC20260147F)**

Your letter ref. TLL/M946/25 dated 11 July 2025 and subsequent submissions received by this department up to 12 February 2026 refer.

Having considered the test report ref. J30517A-Fr5 on 9 February 2026 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tozen Corporation
Country of Origin: Chinese Mainland
Brand: Tozen
Details of Fittings: Twin sphere rubber flexible joint
Model: Twinflex Screwed Type
Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm

Body Markings:

For 15mm, 20mm and 25mm:

TOZEN TWINFLEX 15 • 20 • 25

For 32mm and 40mm:

TOZEN TWINFLEX 32(1¼) 40(1½)

For 50mm:

TOZEN TWINFLEX 50(2)**Expiry Date:**

8 March 2031

Proviso:

The fittings can only be used in flushing water plumbing systems and fresh water fire services systems.


This Authority hereby permits the use of the above fittings in flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.


Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Twinflex Screwed Type