



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2026 T/J(18/2026)

10 March 2026

**Approval of “NUPI” PE Pipes
(General Acceptance No. ZC20260154)**

Your letters dated 6 January 2026 and 5 February 2026 refer.

Having considered the test reports ref. PMA52696 issued on 10 December 2025 by ETS-Testconsult Limited & ref. 250822-2125 issued on 3 February 2026 by Castco Testing Centre Limited and WRAS approval no. 2303548, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: NUPI Industrie Italiane SpA

Country of Origin: Italy

Brand: NUPI

Details of Pipes: PE pipes in blue colour (PE100, SDR11)

Size: 25mm, 315mm

Body Markings: NUPI NADIR PLUS BS EN12201 ISO4427
BS6920 DN/OD x Wall thickness PN16 SDR11
PE100 RC WATER B94HP Batch No.

Expiry Date: 9 March 2031




This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only