



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (10) in WSD 3321/2025 T/J(1312/2025)

16 March 2026

**Approval of “ASAHI” uPVC Pipes
(General Acceptance No. ZC20260174)**

Your letter ref. CYH-WSD-0050 dated 17 December 2025 and subsequent submissions received by this department up to 3 March 2026 refer.

Having considered the test reports ref. BC-SUMMARY-2025-509 and 250821-2068 issued on 14 January 2026 and 30 January 2026 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Asahi Yukizai Corporation

Country of Origin: Japan

Brand: Asahi

Details of Pipes: uPVC pipes in grey colour

Size: 16mm, 20mm, 25mm, 30mm, 40mm, 50mm, 65mm, 75mm, 100mm, 150mm

Body Markings: JIS K6742  **ASAHI** VP size ∞ PVC-U

Expiry Date: 15 March 2031




This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only