



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2026 T/J(82/2026)

20 March 2026

**Approval of “SINOTEC” Ductile Iron Fitting
(General Acceptance No. ZC20260187)**

Your letters ref. 153/2026 and 253/2026 dated 21 January 2026 and 26 February 2026 respectively refer.

Having considered the test reports ref. PMA60001 issued on 5 January 2026 and ref. AGA50471 issued on 18 November 2025 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jilin Senfeng Pipe Co Ltd
Country of Origin: Chinese Mainland
Brand: Sinotec
Details of Fittings: Ductile iron fitting with epoxy powder coating under WRAS approval no. 250355085

Description	Size (mm)
Double Flanged 90° Bend	450

Body Markings: SINOTEC BS EN 545 DI K12 PN16 1.6MPa
size x angle (Manufacture Date)



Expiry Date: 19 March 2031

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed should be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Double Flanged 90° Bend