



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail

wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile

2824 0578

檔號  
Reference

( 2 ) in WSD 3321/2026 T/J(38/2026)

2 April 2026

**Approval of “NEOPERL” Flow Controller  
(General Acceptance No. ZC20260223)**

Your E-Application [file-id: ETJ-GA-20260112-26] dated 14 January 2026 and subsequent submissions received by this department up to 10 March 2026 refer.

Having considered the test report ref. J30944 issued on 30 December 2025 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Neoperl GmbH

**Country of Origin:** Germany

**Brand:** Neoperl

**Details of Fitting:** Flow controller

**Model:** 40.1056.000

**Body Markings:** NEOPERL

**Expiry Date:** 1 April 2031



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only



40.1056.000