



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2026 T/J(161/2026)

14 April 2026

**Approval of “SEAH (PSP)” Galvanized Steel Pipes
(General Acceptance No. ZC20260241FS)**

Your letters ref. BK2026-AC-SeAH(PSP)-003 and BK2026-AC-SeAH(PSP)-003(V2) dated 25 February 2026 and 19 March 2026 respectively refer.

Having considered the test reports ref. BC-SUMMARY-2025-520 and BC-SUMMARY-2026-028 issued on 15 December 2025 and 9 February 2026 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SeAH Steel Corporation

Country of Origin: South Korea

Brand: SeAH (PSP)

Details of Pipes: Galvanized steel pipes

Size: 200mm x 5.6mm, 200mm x 6.3mm,
250mm x 6.3mm, 300mm x 6.3mm



東江水供港



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



15 years+ 同心服務

caringorganisation
Founded by The Hong Kong Social Service Association
香港社會服務會

Body Markings: SĕAH SeAH STEEL EW EN10217-1 P265TR1
 (Size) x (Thickness) x (Length) PSP
 MADE IN KOREA BUN KEE (Production Code)

Expiry Date: 7 September 2031

Proviso: The pipes can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,


 (CHAN Kwok Leung, Douglas)
 for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only