



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2026 T/J(83/2026)

17 April 2026

**Approval of “SINOTEC” Ductile Iron Fittings
(General Acceptance No. ZC20260251)**

Your letter ref. 155/2026 dated 23 January 2026 and subsequent submissions received by this department up to 24 March 2026 refer.

Having considered the test reports ref. PMA52720, PMA52721 and PMA52722 all issued on 17 December 2025 & ref. AGA50471 issued on 18 November 2025 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jilin Senfeng Pipe Co Ltd

Country of Origin: Chinese Mainland

Brand: Sinotec

Details of Fittings: Ductile iron fitting with epoxy powder coating under WRAS approval no. 250355085

Description	Size (mm)
Double Socket 11.25° Bend	80, 100, 150, 200, 250, 300
Double Socket 22.5° Bend	80, 100, 150, 200, 250, 300
Double Socket 45° Bend	80, 100, 150, 200, 250, 300



Description	Size (mm)
Double Socket 90° Bend	80, 100, 150, 200, 250, 300
Double Socket Tee with Flanged Branch	200x200x100, 300x300x150
Double Socket Taper	200x100, 300x150

Body Markings:

For Double Socket Tees with Flanged Branch:
 SINOTEC BS EN 545 DI K12 PN16 1.6MPa
 size x size (Manufacture Date)

For Double Socket Tapers:
 SINOTEC BS EN 545 DI K12 1.6MPa
 size x size (Manufacture Date)

For Others:
 SINOTEC BS EN 545 DI K12 1.6MPa
 size x angle (Manufacture Date)

Expiry Date:

16 April 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,


 (CHAN Kwok Leung, Douglas)
 for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Double Socket 11.25° Bend



Double Socket 22.5° Bend



Double Socket 45° Bend



Double Socket 90° Bend



Double Socket Tee
with Flanged Branch



Double Socket Taper