



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025 T/J(844/2025)

22 April 2026

**Approval of “PHILMAC” Pressure Reducing Valves
(General Acceptance No. ZC20260260FS)**

Your E-Application [file-id: ETJ-GA-20250819-233] dated 19 August 2025 and subsequent submissions received by this department up to 24 March 2026 refer.

Having considered the test report ref. BC-SUMMARY-2025-326 issued on 7 August 2025 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Philmac Pty Ltd

Country of Origin: Australia

Brand: Philmac

Details of Fittings: Copper alloy pressure reducing valve

Model and Size: Cat no. 2650 – 80mm
Cat no. 2675 – 100mm

Body Markings: PHILMAC ↓

Expiry Date: 21 April 2031



東江水供港
Tung Chung Water Supply Project



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



15 years+ 同心展開懷
caring organisation
Awarded by The Hong Kong Council of Social Service
香港社會服務會頒發

Proviso: The fittings can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Cat no. 2650

Cat no. 2675