



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2026 T/J(23/2026)

24 April 2026

**Approval of “NEOPERL” Flow Controller
(General Acceptance No. ZC20260264)**

Your E-Application [file-id: ETJ-GA-20260108-11] dated 14 January 2026 and subsequent submissions received by this department up to 1 April 2026 refer.

Having considered the test report ref. J30912r1 issued on 31 March 2026 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Neoperl United Kingdom

Country of Origin: UK

Brand: Neoperl

Details of Fitting: Flow controller

Model: 40.7559.000

Body Markings: 

Expiry Date: 23 April 2031



東江水供港



香港環保卓越大獎
Hong Kong Award for Environmental Excellence



15 years caring organisation
同心共關懷
Announced by The Hong Kong Council of Social Service
獲香港社會服務界頒發


This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



40.7559.000