水 務 署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞 *e-mail* wsdinfo@wsd.gov.hk

電 話 *Telephone*

圖文傳真 *Facsimile* 2824 0578

檔 號 *Reference* (4) in WSD 3321/2026 T/J(164/2026)

27 April 2026

Approval of "ACE" Gate Valves
(General Acceptance No. ZC20260271)

Your letters ref. WSD/AP-24022026-1 and WSD/AP-24022026-1(1) dated 24 February 2026 and 8 April 2026 respectively refer.

Having considered the test report ref. 254110PC251262C issued on 17 March 2026 by Fugro Technical Services Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Yantai Valve Factory
Country of Origin:	Chinese Mainland
Brand:	ACE
Details of Fittings:	Ductile iron resilient seated gate valve with epoxy powder coating under WRAS approval no. 250355085
Model:	CV-101WHA
Size:	65mm, 80mm, 100mm, 150mm, 200mm
Body Markings:	ACE Size in DN PN16 DI RES BS EN 1074-2 BS 5163-1

東江水供港
香港環境卓越大獎
15 years+ 同心展關懷 caringorganisation

Expiry Date: 26 April 2031

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,

(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

CV-101WHA