



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2026 T/J(266/2026)

27 April 2026

**Approval of “SRI” Flexible Joints
(General Acceptance No. ZC20260274FS)**

Your letter ref. AWSD0002/26 dated 25 March 2026 refers.

Having considered the test report ref. J31044A-F issued on 24 March 2026 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Steel Recon Industries Sdn Bhd

Country of Origin: Chinese Mainland

Brand: SRI

Details of Fittings: Double sphere rubber flexible joint

Model and Size:

MIS252-MS-50TE	– 50mm
MIS252-MS-65TE	– 65mm
MIS252-MS-80TE	– 80mm
MIS252-MS-100TE	– 100mm
MIS252-MS-150TE	– 150mm
MIS252-MS-200TE	– 200mm

Body Markings: SRI size in DN BS4504 PN16



東江水供港



香港環境卓越大獎



獲頒發由香港社會服務局

Expiry Date: 6 May 2031

Proviso: The fittings can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



MIS252-MS-50TE

MIS252-MS-65TE

MIS252-MS-80TE

MIS252-MS-100TE

MIS252-MS-150TE

MIS252-MS-200TE