



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2026 T/J(40/2026)

6 May 2026

**Approval of "ROCA" Kitchen Mixer
(General Acceptance No. ZC20260289)**

Your E-Application [file-id: ETJ-GA-20251210-414] dated 15 January 2026 and subsequent submissions received by this department up to 14 April 2026 refer.

Having considered the test report ref. RROC003r3 issued on 13 April 2026 by Ideal Test Consultants Ltd. and WRAS certificates, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Roca Sanitary Ware (Suzhou) Co Ltd

Country of Origin: Chinese Mainland

Brand: Roca

Details of Fitting: 1/2" Single lever kitchen mixer with
1) 1 no. of flexible hose approved by UK's WRAS under ref. 2201334 &
2) 1 no. of flexible hose approved by UK's WRAS under ref. 250412002

Model: A5A851FXXX
(where "XXX" denotes the code of colour)

Body Markings: **Roca**



Expiry Date: 5 May 2031

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."


A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



A5A851FXXX