



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(6) in WSD 3321/2026 T/J(107/2026)

6 May 2026

**Approval of "HENSUN" Stainless Steel Pipes
(General Acceptance No. ZC20260290)**

Your letters dated 2 February 2026, 26 February 2026 and 15 April 2026 refer.

Having considered the test report ref. 252475PC251040A issued on 17 March 2026 by Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Hensun Pipe Industry Co Ltd

Country of Origin: Chinese Mainland

Brand: Hensun

Details of Pipes: Stainless steel pipes - Series 1 (316L)

Size: 15mm, 22mm, 28mm, 35mm, 42mm, 54mm, 66.7mm, 76.1mm

Body Markings: 佛山市恒合信管業有限公司 O.D x thickness
AISI 316L / 1.4404 EN10312-S1

Expiry Date: 5 May 2031



This Authority hereby permits the use of the above pipes in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only