



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2026 T/J(146/2026)

6 May 2026

**Approval of “PEGLER” Gate Valves
(General Acceptance No. ZC20260291)**

Your letters ref. Q-1747/26, Q-1774/26 and Q-1783/26 dated 13 February 2026, 30 March 2026 and 14 April 2026 respectively refer.

Having considered the test report ref. BC-SUMMARY-2026-018 issued on 9 March 2026 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Aalberts Integrated Piping Systems Ltd

Country of Origin: UK

Brand: Pegler

Details of Fitting: Copper alloy gate valve

Model: 1068

Size: 2½", 3", 4"

Body Markings: PEGLER ENGLAND Size BR 125 PN

Expiry Date: 5 May 2031




This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



1068