



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2026 T/J(265/2026)

14 May 2026

**Approval of “SRI” Flexible Joints
(General Acceptance No. ZC20260313FS)**

Your letters ref. AWSD0001/26 and AWSD0001/26(2) dated 25 March 2026 and 21 April 2026 respectively refer.

Having considered the test report ref. J31041A-E issued on 24 March 2026 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Steel Recon Industries Sdn Bhd

Country of Origin: Chinese Mainland

Brand: SRI

Details of Fittings: Single sphere rubber flexible joint

Model and Size:

MIS253-MS-50TE	– 50mm
MIS253-MS-65TE	– 65mm
MIS253-MS-80TE	– 80mm
MIS253-MS-100TE	– 100mm
MIS253-MS-150TE	– 150mm

Body Markings: SRI Size in DN BS4504 PN16



Expiry Date: 13 May 2031

Proviso: The fittings can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.


Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



MIS253-MS-50TE
MIS253-MS-65TE
MIS253-MS-80TE
MIS253-MS-100TE
MIS253-MS-150TE