



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2026 T/J(96/2026)

20 May 2026

**Approval of "G.H." Ductile Iron Fittings
(General Acceptance No. ZC20260322)**

Your letter dated 2 February 2026 and subsequent submissions received by this department up to 29 April 2026 refer.

Having considered the test reports ref. PMA51743A issued on 16 October 2025 & ref. AGA50321 issued on 8 August 2025 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Liaoning Ever Metal Forming Tech Co Ltd

Country of Origin: Chinese Mainland

Brand: G.H.

Details of Fittings: Ductile iron fittings with epoxy powder coating under WRAS approval no. 260455002

Description	Size (mm)
Double Socket Taper	100x80, 150x80, 150x100, 200x100, 200x150, 250x150, 250x200, 300x150, 300x200, 300x250, 350x200, 350x250, 400x200, 400x250, 400x300,



Description	Size (mm)
Double Socket Taper	450x250, 450x300, 450x400, 500x400, 500x450, 600x400, 600x450, 600x500
Double Flanged Taper PN16	100x80, 150x80, 150x100, 200x100, 200x150, 250x150, 250x200, 300x150, 300x200, 300x250, 350x200, 350x250, 400x200, 400x250, 400x300, 450x250, 450x300, 450x400, 500x400, 500x450, 600x400, 600x450, 600x500

Body Markings:

For Double Socket Taper:

G.H. BS EN 545 DI K12 size x size

For Double Flanged Taper:

G.H. BS EN 545 DI K12 PN16 size x size

Expiry Date:

19 May 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double Socket Taper



Double Flanged Taper PN16