



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2025 T/J(983/2025)

28 May 2026

**Approval of “VP” Ball Valves
(General Acceptance No. ZC20260333F)**

Your E-Application [file-id: ETJ-GA-20250918-284] dated 22 September 2025 and subsequent submissions received by this department up to 5 May 2026 refer.

Having considered the test report ref. 252022PC250784B issued on 5 May 2026 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hershey Valve Co Ltd

Country of Origin: Taiwan, China

Brand: VP

Details of Fittings: uPVC compact ball valve

Model: VP-910 (White Color)

Size: ½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4"

Body Markings:  size in inch TAIWAN



Expiry Date: 27 May 2031

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing systems.


This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



VP-910 (White Color)