



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2026 T/J(334/2026)

29 May 2026

**Approval of "AQUAPOWER" Strainer
(General Acceptance No. ZC20260338)**

Your letters ref. AP/012/DF/2026 and AP/014/DF/2026 dated 14 April 2026 and 4 May 2026 respectively refer.

Having considered the test report ref. 253570PC251086F issued on 30 April 2026 by Fugro Technical Services Limited and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SLK Manufacturing Ltd

Country of Origin: Chinese Mainland

Brand: Aquapower

Details of Fitting: Ductile iron Y-strainer with epoxy powder coating under WRAS approval no. 240455041

Model: AP-Y-DN100-350

Size: 100mm

Body Markings: AQUA POWER DI DN100 L350
PN16 RJT2507 →



Expiry Date: 28 May 2031

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



AP-Y-DN100-350