



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2026 T/J(153/2026)

3 June 2026

**Approval of “KITZ” Ball Valves
(General Acceptance No. ZC20260349FS)**

Your E-Application [file-id: ETJ-GA-20260224-85] dated 25 February 2026 and subsequent submissions received by this department up to 8 May 2026 refer.

Having considered the test report ref. BC-SUMMARY-2025-120 issued on 24 February 2026 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kitz

Country of Origin: Thailand

Brand: Kitz

Details of Fittings: Copper alloy ball valve

Model: SZA

Size: ½", ¾", 1", 1¼", 1½", 2", 2½"

Body Markings: KITZ (Inch Size)



Expiry Date: 2 June 2031

Proviso: The fittings can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



SZA