



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2026 T/J(229/2026)

10 June 2026

**Approval of “YUE HING” Hydrant Valve
(General Acceptance No. ZC20260375FS)**

Your letters ref. WSD/AP-17032026-2 and WSD/AP-17032026-2-2(1) dated 17 March 2026 and 13 May 2026 respectively refer.

Having considered the test report ref. J31016Ar1 issued on 23 April 2026 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yue Hing Machine Factory Ltd

Country of Origin: Chinese Mainland

Brand: Yue Hing

Details of Fitting: 80mm Copper alloy low pressure hydrant valve

Model: Y106P

Body Markings:  80 Y106P SI

Expiry Date: 9 June 2031

Proviso: The fitting can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above fitting in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water fire service systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Y106P