



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2026 T/J(468/2026)

12 June 2026

**Approval of “WEDNESBURY” Copper Pipe
(General Acceptance No. ZC20260392)**

Your letter ref. CYH-WSD-0060 dated 14 May 2026 refers.

Having considered the test report ref. BC-SUMMARY-2025-476 issued on 20 April 2026 by Castco Testing Centre Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Mueller Europe Limited

Country of Origin: UK

Brand: Wednesbury

Details of Pipe: Copper pipe (Table X)

Temper	Size (mm)
R290	159 x 2

Body Markings: WEDNESBURY STREAMLINE GB
(DN) x (Wall Thickness) COPPER TUBE TO EN 1057
(Production Code) MADE IN UK



Expiry Date: 9 July 2031

This Authority hereby permits the use of the above pipe in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only