



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(9) in WSD 3321/2026 T/J(231/2026)

23 June 2026

**Approval of "KING LION" uPVC Pipes
(General Acceptance No. ZC20260408F)**

Your letter ref. HK/KLSD/LL26/005 and dated 18 March 2026 and subsequent submissions received by this department up to 28 May 2026 refer.

Having considered the test report ref. 04334W500012D issued on 14 May 2026 by Material Tech Company Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: King Lion PVC Pipes & Fittings Mfy Limited

Country of Origin: Chinese Mainland

Brand: King Lion

Details of Pipes: uPVC pipes in grey colour (Class E)

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm, 75mm, 100mm, 150mm

Body Markings:  KING LION UPVC PIPE
BS3505 CLASS "E" size in mm

Expiry Date: 22 June 2031



東江水供港



香港環境卓越獎
Hong Kong Awards for Environmental Excellence



15 years+ 同心展關懷
caring organisation
Awarded by the Hong Kong Council of Social Service
香港社會服務會頒發

Proviso:

As the pipes have not been tested for use in contact with water intended for human consumption, the pipes can only be used in flushing water plumbing system.


This Authority hereby permits the use of the above pipes in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the flushing water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only