



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(10) in WSD 3321/2025 T/J(1222/2025)

25 June 2026

**Approval of “SINO-FLEX” Flexible Joint
(General Acceptance No. ZC20260417)**

Your letter ref. 1201/2025 dated 1 December 2025 and subsequent submissions received by this department up to 27 May 2026 refer.

Having considered the test reports ref. PMA52465C and AGA50471 issued on 7 May 2026 and 13 November 2025 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yung Yu Special Joint Co Ltd

Country of Origin: Taiwan, China

Brand: Sino-Flex

Details of Fitting: Ductile iron flexible joint with epoxy powder coating under WRAS approval no. 250355085

Model: Double Globes Type

Size: 250mm

Body Markings: SINO-FLEX



東江水供港



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



15 years+ caring organisation

Accredited by The Hong Kong Council of Social Service
香港社會服務會認證

Expiry Date:

24 June 2031

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Double Globes Type