



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(10) in WSD 3321/2026 T/J(78/2026)

2 July 2026

**Approval of "GAPEX" PE Pipes
(General Acceptance No. ZC20260429)**

Your letter ref. GA2K26-L126-WSD dated 26 January 2026 and subsequent submissions received by this department up to 5 June 2026 refer.

Having considered the test reports ref. PMA51499C issued on 28 May 2026 and ref. AGA50306A issued on 12 February 2026 by ETS-Testconsult Limited and WRAS approval no. 2207522, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Fengye Pipe Industrial Co Ltd

Country of Origin: Chinese Mainland

Brand: Gapex

Details of Pipes: PE pipes in blue colour (PE100, SDR11)

Size: 25mm, 32mm, 50mm, 500mm, 630mm

Body Markings: EN12201 Gapex DN/OD x Wall thickness
SDR11 PN16W/P PE100RC Batch no.
Production date Barcode Gapex



Expiry Date: 1 July 2031

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only