



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone

圖文傳真  
Facsimile

2824 0578

檔號  
Reference

( 2 ) in WSD 3321/2026 T/J(478/2026)

8 July 2026

**Approval of "KOHLER" Basin Mixer  
(General Acceptance No. ZC20260464)**

Your E-Application [file-id: ETJ-GA-20260519-237] dated 20 May 2026 and subsequent submission received by this department on 9 June 2026 refer.

Having considered the test report ref. J31252 issued on 19 May 2026 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Kohler

**Country of Origin:** Chinese Mainland

**Brand:** Kohler

**Details of Fitting:** 3/8" Single lever basin mixer

**Model:** K-23472T-XX-YY  
(where "XX" denotes the code of handle and "YY" denotes the code of colour)

**Body Markings:** KOHLER

**Expiry Date:** 31 October 2031



東江水供港



香港環境卓越大獎  
Hong Kong Awards for Environmental Excellence



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only



K-23472T-XX-YY