



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail      wsinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile      2824 0578

檔號  
Reference      ( 4 ) in WSD 3321/2026 T/J(536/2026)

22 July 2026

**Approval of “JOHNSON SUISSE” Flush Valve  
(General Acceptance No. ZC20260516F)**

Your letters ref. RSL-HK-2026-LTR0014B and RSL-HK-2026-LTR0014B1 dated 1 June 2026 and 24 June 2026 respectively refer.

Having considered the test report ref. J31194 issued on 27 May 2026 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:**      Roca (China) Co Ltd

**Country of Origin:**          Chinese Mainland

**Brand:**                          Johnson Suisse

**Details of Fitting:**           60mm Plastic dual flush valve

**Model:**                          WBSP0000086T

**Body Markings:**              *JohnsonSuisse*

**Expiry Date:**                  21 July 2031

**Proviso:**

As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The flushing volume of the flushing valve should be adjusted to suit the design of the toilet bowl so that wastes can be cleared effectively by a single flush."

"The fitting should be used within the range of working pressures specified by the manufacturer." AND


"The installed fitting should not result in backflow of water that will contaminate the flushing water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC               ] - with soft copy only



WBSP0000086T