



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2026 T/J(370/2026)

24 July 2026

**Approval of “SRI” Gate Valves
(General Acceptance No. ZC20260525FS)**

Your letter ref. AWS0008/26 dated 21 April 2026 and subsequent submissions received by this department up to 29 June 2026 refer.

Having considered the test report ref. J31046A-Er2 issued on 25 June 2026 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Steel Recon Industries Sdn Bhd

Country of Origin: Chinese Mainland

Brand: SRI

Details of Fitting: Ductile iron gate valve

Model and Size:
HYD089-DI65PN25 – 65mm
HYD089-DI80PN25 – 80mm
HYD089-DI100PN25 – 100mm
HYD089-DI150PN25 – 150mm
HYD089-DI200PN25 – 200mm



Body Markings: **SRI** DI Size in DN

Expiry Date: 23 July 2031

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



HYD089-DI65PN25
HYD089-DI80PN25
HYD089-DI100PN25
HYD089-DI150PN25
HYD089-DI200PN25