



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (2) in WSD 3321/2026 T/J(385/2026)

24 July 2026

**Approval of "GIACOMINI" Check Valves  
(General Acceptance No. ZC20260526FS)**

Your E-Application [file-id: ETJ-GA-20260424-196] dated 27 April 2026 and subsequent submissions received by this department up to 29 June 2026 refer.

Having considered the test report ref. J31081A-Cr1 issued on 2 June 2026 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Giacomini SpA

**Country of Origin:** Italy

**Brand:** Giacomini

**Details of Fittings:** Copper alloy swing check valve

**Model and Size:** N5Y003 - ½"  
N5Y004 - ¾"  
N5Y005 - 1"

**Body Markings:** Size in DN PN16 Size in inch  
MADE IN ITALY ➡



**Expiry Date:** 23 July 2031

**Proviso:** The fittings can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,

  
(CHAN Kwok Leung, Douglas)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only



N5Y003

N5Y004

N5Y005