



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2026 T/J(403/2026)

27 July 2026

**Approval of “BOLTON” Ductile Iron Fittings
(General Acceptance No. ZC20260533)**

Your letters ref. AL/5550/WSD/GA+ and AL/5550-1/WSD/GA+ dated 30 April 2026 and 2 July 2026 respectively refer.

Having considered the test reports ref. PMA60553A issued on 2 June 2026 by ETS-Testconsult Ltd. and ref. 250416-2334 issued on 25 July 2025 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Chanshan Foundry Co Ltd
Country of Origin: Chinese Mainland
Brand: Bolton
Details of Fittings: Ductile iron fittings with internal cement mortar lining

Description	Model	Size (mm)
Double Flanged 90° Duckfoot Bend PN16	FCD900	400, 450

Body Markings: Bolton FZ BS EN 545 DI K12 PN16
Size x 90 Production ID



Expiry Date: 26 July 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Double Flanged 90°
Duckfoot Bend PN16