



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞  
e-mail      wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile      2824 0578

檔號  
Reference      ( 4 ) in WSD 3321/2026 T/J(434/2026)

30 July 2026

**Approval of “KURIMOTO” Ductile Iron Pipes  
(General Acceptance No. ZC20260544)**

Your letters ref. 515/2026 and 710/2026 dated 7 May 2026 and 3 July 2026 respectively refer.

Having considered the test reports ref. PMA61122 issued on 27 April 2026 and ref. AGA60330 issued on 29 June 2026 by ETS-Testconsult Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Kurimoto Ltd

**Country of Origin:** Taiwan, China

**Brand:** Kurimoto

**Details of Pipes:** K12 Ductile iron socket and spigot pipes with internal cement mortar lining under WRAS approval no. 2208514

**Size:** 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

**Body Markings:** KURIMOTO ✕ BS EN 545 size x length K12

**Expiry Date:** 29 July 2031




This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.


Yours faithfully,



(CHAN Kwok Leung, Douglas)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only



K12 Ductile iron socket and spigot pipes