



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2026 T/J(495/2026)

31 July 2026

**Approval of “ARON” uPVC Pipes
(General Acceptance No. ZC20260548F)**

Your letter ref. MH20260519 dated 19 May 2026 and subsequent submissions received by this department up to 7 July 2026 refer.

Having considered the test report ref. BC-SUMMARY-2026-119 issued on 17 April 2026 by Castco Testing Centre Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Aron Kasei Co Ltd

Country of Origin: Japan

Brand: Aron

Details of Pipes: uPVC pipes in grey colour (Class E)

Size: 16mm, 20mm, 25mm, 30mm, 65mm



Body Markings:

Size (mm)	Body Marking
16	C)(A)JIS JW JW0406003 JIS K 6742 アロンパイプ VP 16 N (Production Code) スイドウ ∞ PVC-U
20	C)(A)JIS JW JW0406003 JIS K 6742 アロンパイプ VP 20 N (Production Code) スイドウ ∞ PVC-U
25	C)(A)JIS JW JW0406003 JIS K 6742 アロンパイプ VP 25 N (Production Code) スイドウ ∞ PVC-U
30	C)(A)JIS JW JW0406003 JIS K 6742 アロンパイプ VP 30 N (Production Code) スイドウ ∞ PVC-U
65	(A)JIS JW JW0307018 JIS K 6741 アロンパイプ VP 65 N ∞ PVC-U CS (Production Code)

Expiry Date: 30 July 2031

Proviso: As the pipes have not been tested for use in contact with water intended for human consumption, the pipes can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipes in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the flushing water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only