



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (8) in WSD 3321/2026 T/J(368/2026)

5 August 2026

**Approval of “KOTOMA” Butterfly Valves
(General Acceptance No. ZC20260559FS)**

Your letter ref. AWSD0006/26 dated 20 April 2026 and subsequent submissions received by this department up to 8 July 2026 refer.

Having considered the test report ref. J31040A-Er1 issued on 8 June 2026 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Henry Engineering & Supplies

Country of Origin: Chinese Mainland

Brand: Kotoma

Details of Fitting: Ductile iron grooved type butterfly valve

Model and Size: KT-65-BV - 65mm
KT-80-BV - 80mm
KT-100-BV - 100mm
KT-150-BV - 150mm
KT-200-BV - 200mm



東江水供港



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



15 years caring organisation
Awarded by the Hong Kong Council of Social Service
香港社會服務會

Body Markings: KOTOMA Model Size Max Pressure

Expiry Date: 4 August 2031

Proviso: The fittings can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



KT-65-BV
KT-80-BV
KT-100-BV
KT-150-BV
KT-200-BV