



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2026 T/J(506/2026)

5 August 2026

**Approval of “珠江” Galvanized Steel Pipes
(General Acceptance No. ZC20260561FS)**

Your letters ref. 202605-024 and 202605-024 (V2) dated 22 May 2026 and 7 July 2026 respectively refer.

Having considered the test reports ref. BC-SUMMARY-2026-178 and BC-SUMMARY-2026-179 both issued on 14 May 2026 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Pearl River Pipes Group (Jiangmen) Co Ltd

Country of Origin: Chinese Mainland

Brand: 珠江

Details of Pipes: Galvanized steel pipes (class medium & class heavy)

Size: 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm

Body Markings:

珠●江 EN10255 : 2004 SERIES (Class)
W (Size) x (Length) (Production Code)

Expiry Date:

4 August 2031

Proviso:

The pipes can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only