



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2026 T/J(513/2026)

14 August 2026

**Approval of "VADO" Basin Mixers
(General Acceptance No. ZC20260581)**

Your letter ref. GTBM-ADM-LT-046-26 dated 27 May 2026 and subsequent submissions received by this department up to 24 July 2026 refer.

Having considered the test report ref. RGTC302 issued on 21 May 2026 by Ideal Test Consultants Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Vado

Country of Origin: UK

Brand: Vado

Details of Fittings: 1/2" Single lever basin mixer

Model: EDI-100/SB-C/P, EDI-100/CC-C/P,
IND-EDI100/SB-BLK, IND-EDI100/SB-BG,
IND-EDI100/SB-BN, IND-EDI100/SB-BRG,
IND-EDI100/SB-BRN, IND-EDI100/SB-BRZ

Body Markings:



Expiry Date: 13 August 2031

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."


A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,


(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



EDI-100/SB-C/P



EDI-100/CC-C/P



IND-EDI100/SB-BLK



IND-EDI100/SB-BG



IND-EDI100/SB-BN



IND-EDI100/SB-BRG



IND-EDI100/SB-BRN



IND-EDI100/SB-BRZ