



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail

wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile

2824 0578

檔號  
Reference

( 2 ) in WSD 3321/2026 T/J(175/2026)

21 August 2026

**Approval of “TOYO” Check Valves  
(General Acceptance No. ZC20260596)**

Your E-Application [file-id: ETJ-GA-20260224-84] dated 4 March 2026 and subsequent submissions received by this department up to 29 July 2026 refer.

Having considered the test report ref. BC-SUMMARY-2025-468 issued on 10 June 2026 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Kitz Corporation  
**Country of Origin:** Thailand  
**Brand:** TOYO  
**Details of Fittings:** Copper alloy swing check valve  
**Model:** 236R  
**Size:** 15mm, 20mm, 25mm, 32mm, 40mm, 50mm  
**Body Markings:** RED-WHITE  (Inch) 125S 200 WOG ➡



東江水供港



香港環境卓越大獎  
Hong Kong Award for Environmental Excellence



caringorganisation

Awards by The Hong Kong Council of Social Service  
香港社會服務會頒發

**Expiry Date:** 20 August 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,

  
(CHAN Kwok Leung, Douglas)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only



236R