



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2026 T/J(549/2026)

24 August 2026

**Approval of “BEL” Ductile Iron Pipes
(General Acceptance No. ZC20260602)**

Your letters dated 1 June 2026, 7 July 2026 and 30 July 2026 refer.

Having considered the test reports ref. PMA61389B and PMA61390B both issued on 27 July 2026 and ref. AGA60239 and AGA60238 both issued on 30 April 2026 by ETS-Testconsult Limited and WRAS certificates, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Xinxing Ductile Iron Pipes Co Ltd

Country of Origin: Chinese Mainland

Brand: BEL

Details of Pipes: K9 and K12 Ductile iron pipes with welded-on flanged with internal epoxy seal coat (under WRAS approval no. 241055069) for cement mortar lining (under WRAS approval no. 240355013)

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm



Body Markings:

For K9:

BEL BS EN 545 size x length
 K9 D/F 1.6Mpa PN16

For K12:

BEL BS EN 545 size x length
 K12 D/F 1.6Mpa PN16

Expiry Date:

23 August 2031


This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.


Yours faithfully,




(CHAN Kwok Leung, Douglas)
 for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



K9 Ductile iron pipes with welded-on flanged



K12 Ductile iron pipes with welded-on flanged