



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2026 T/J(149/2026)

31 August 2026

**Approval of “RIGEL” Sensor Taps
(General Acceptance No. ZC20260613)**

Your E-Application [file-id: ETJ-GA-20260216-72] dated 24 February 2026 and subsequent submissions received by this department up to 4 August 2026 refer.

Having considered the test report ref. J30961Ar2 issued on 7 July 2026 by Nutek Systems (HK) Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Rigel Technology (S) Pte Ltd

Country of Origin: Chinese Mainland

Brand: Rigel

Details of Fittings: 1/2" Deck mounted sensor tap with 1 no. of flexible hose approved by UK's WRAS under ref. 241102028

Model: H1-R-SSTL600D, H1-R-SSTLW600D

Body Markings: 
rigel

Expiry Date: 30 August 2031

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."


A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,


(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



H1-R-SSTL600D



H1-R-SSTLW600D