



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2026 T/J(562/2026)

7 September 2026

**Approval of “HOLLY” Copper Fittings
(General Acceptance No. ZC20260632)**

Your E-Application [file-id: ETJ-GA-20260604-269] dated 9 June 2026 and subsequent submissions received by this department up to 12 August 2026 refer.

Having considered the test report ref. BC-SUMMARY-2026-196 issued on 21 May 2026 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Taizhou Smart Pipe Line Tech Co Ltd

Country of Origin: Chinese Mainland

Brand: Holly

Details of Fittings: Copper fittings with solder ring connection ends

Description	Model	Size (mm)
90° Elbow	H-SE01	15, 22, 28, 35, 42, 54
45° Elbow	H-SE02	15, 22, 28, 35, 42, 54
Reducing Elbow	H-SE03	22x15
Equal Tee	H-ST01	15, 22, 28, 35, 42, 54

Description	Model	Size (mm)
Reducing Tee	H-ST02	22x15x15, 22x15x22, 22x22x15, 28x28x22, 35x35x22, 35x35x28, 42x42x22, 42x42x28, 54x54x22
Straight Coupling	H-SC01	15, 22, 28, 35, 42, 54
Reducer	H-SC02	22x15, 28x22, 35x22, 35x28
End Cap	H-SC03	15, 22

Body Markings: EN1254-1  HOLLY (Size)

Expiry Date: 6 September 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,


(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



90° Elbow



45° Elbow



Reducing Elbow



Equal Tee



Reducing Tee



Straight Coupling



Reducer



End Cap