



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2026 T/J(668/2026)

7 September 2026

**Approval of "S.H." Ball Valves
(General Acceptance No. ZC20260633F)**

Your letters both ref. MH20260715-1 dated 15 July 2026 and 11 August 2026 refer.

Having considered the test report ref. BC-SUMMARY-2026-216 issued on 18 June 2026 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shie Yu Machine Parts Industrial Co Ltd

Country of Origin: Taiwan, China

Brand: S.H.

Details of Fittings: uPVC ball valve in grey colour

Model and Size:
CC100-016G - ½"
CC100-020G - ¾"
CC100-025G - 1"
CC100-032G - 1¼"
CC100-038G - 1½"
CC100-050G - 2"



CC100-065G - 2½"

CC100-075G - 3"

Body Markings:

 TAIWAN (Size) (Production Code)
UPVC COMPACT BALL VALVE

Expiry Date:

13 September 2031

Proviso:

As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing systems.


This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.


Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,


(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



CC100-016G
CC100-020G
CC100-025G
CC100-032G
CC100-038G
CC100-050G



CC100-065G
CC100-075G