



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2026 T/J(696/2026)

8 September 2026

**Approval of “VALVEMAKER” Gate Valves
(General Acceptance No. ZC20260638)**

Your letter ref. BK2026-AC-VALVEMAKER-DI-027 dated 23 July 2026 and subsequent submission received by this department on 17 August 2026 refer.

Having considered the test reports ref. BC-SUMMARY-2025-388 and BC-SUMMARY-2025-399 both issued on 29 August 2025 and ref. 260610-2749 issued on 3 July 2026 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Yantai Valve Factory
Country of Origin:	Chinese Mainland
Brand:	Valvemaker
Details of Fittings:	Ductile iron metal seated gate valve with epoxy powder coating under WRAS approval no. 260255001
Model:	16-GV (Hand Wheel), 16-GV (Stem Cap)
Size:	65mm, 80mm, 100mm, 150mm, 200mm, 250mm, 300mm



東江水供港



香港環境卓越大獎
Hong Kong Award for Environmental Excellence



Provided by The Hong Kong Council of Social Service
香港社會服務會

Body Markings:

V-MAKER (Production Code) (DN)
SG CF PN16 BS5163-1 EN1074-2

Expiry Date:

31 January 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



16-GV (Hand Wheel)



16-GV (Stem Cap)