



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (8) in WSD 3321/2026 T/J(292/2026)

14 September 2026

**Approval of “DOLPHINA” UPVC Fittings
(General Acceptance No. ZC20260658F)**

Your letter ref. BK2026-AC-Dolphinaf-011 dated 30 March 2026 and subsequent submissions received by this department up to 26 August 2026 refer.

Having considered the test report ref. 253924PC251441(4)B issued on 8 July 2026 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Ammei Shi Ye Co Ltd

Country of Origin: Chinese Mainland

Brand: Dolphina

Details of Fittings: uPVC fittings in white colour

Description	Size (inch)
90° Male Thread Elbow	1/2", 3/4"

Body Markings:



(Size) x 90° PVC-U BS 4346-1
BS EN ISO 1452-3 (Product Code)

Expiry Date:

13 September 2031



Proviso:

As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.


This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



90° Male Thread Elbow