



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2026 T/J(686/2026)

5 October 2026

**Approval of “WAH HUNG” Gate Valves
(General Acceptance No. ZC20260702)**

Your E-Application [file-id: ETJ-GA-20260719-365] dated 20 July 2026 and subsequent submission received by this department on 7 September 2026 refer.

Having considered the test reports ref. 253205PC260195B issued on 3 September 2026 and ref. 230535EN230666 issued on 1 August 2023 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Wah Nan Fire Fighting Equipment Co Ltd

Country of Origin: Chinese Mainland

Brand: Wah Hung

Details of Fittings: Ductile iron resilient seated gate valve with epoxy coating

Model: WH010-C (PN25)

Size: 80mm, 100mm, 150mm, 200mm

Body Markings:  Size in DN PN25

Expiry Date: 4 October 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



WH010-C (PN25)