



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2021 T/J(642/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

25 June 2021

**Approval of "PCC" Stainless Steel Pipes
(General Acceptance No. C20210654)**

Your letter ref. 21123 dated 26 April 2021 refers.

Having considered the test report ref: 192879PC190339(2) issued on 8 April 2021 by Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: GX GXM Piping Technology Co Ltd

Country of Origin: the Mainland of China

Brand: PCC

Details of Pipes: Stainless steel pipes - Series 1 (316L)

Size: 15mm, 22mm, 28mm, 35mm, 42mm, 54mm, 66.7mm, 76.1mm, 108mm

Body Markings: PI size x thickness 316L EN10312-1

Expiry Date: 19 July 2025

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only